#### REQUEST FOR BOARD ACTION

## Henderson County Board of Commissioners

Meeting Date: November 6, 2006

Subject: Water Line Extension – Summit Springs

**Attachments:** Project Summary

Engineer's Report County Review Sheet

#### **Summary of Request:**

The City of Hendersonville has requested County comments on proposed water line extension for Summit Springs.

A City of Hendersonville Project Summary sheet, with backup documents and County review sheet with staff comments are attached for Board review and action.

#### **County Manager's Comments:**

The County Manager recommends approval of this water line extension and directs staff to convey the County's comments to the City of Hendersonville upon Board approval.

OFFICERS:

Greg Newman Mayor Barbara Volk Mayor Pro-Tem Chris A. Carter City Manager

### CITY OF HENDERSONVILLE

"The City of Four Seasons"

WATER AND SEWER DEPARTMENT Lee Smith, Utilities Director CITY COUNCIL:

BARBARA VOLK

JON LAUGHTER

WILLIAM O'CAIN

JEFF COLLIS

October 10, 2006

Henderson County Planning Department Kathleen Scanlan 101 East Allen Street Hendersonville, NC 28792

Re: REQUEST FOR COMMENTS Summit Springs – Off Site File # S080106

Dear Ms. Scanlan:

The above referenced project lies within the jurisdiction of Henderson County and is hereby submitted to your department for review and approval. Enclosed, please find the following information:

Project Summary Line Details

Please return the Project summary upon completion along with your department's projects processing review form.

If you have any questions, please contact me at 233-3206 or Lee Smith, Director @ 233-3211.

rwiggins@cityofhendersonville.org lsmith@cityofhendersonville.org

Sincerely.

Rhonda Wiggins

Utilities Project Coordinator

305 Williams Street Hendersonville, NC 28792-4461 e-mail: lsmith@cityofhendersonville.org Phone: (828) 697-3063 Fax: (828) 697-3089 www.cityofhendersonville.org

# City of Hendersonville - Project Summary Water Line Extension Summit Springs - Off Site

Date: September 18, 2006

This is a project to extend existing water lines to provide water service to proposed single family subdivision development. This extension will serve a total of one hundred sixty seven (167) lots.

This project is under the reviewing jurisdiction of: Henderson County.

This project requires approximately 1,400 linear feet of water line sized as following:

Description:

Approximate Length

8" DIP

1.400'

Fire Protection will be provided by the installation of 3 fire hydrant(s).

The entire cost of the proposed water line extension is to be paid for by Summit Springs, LLC of Hendersonville, NC.

Water pressure and flow in this area is as follows:

Static Pressure:

68 PSI

Hydrant 07-0726

Residual:

46 PSI

Hydrant 07-0726

Flow:

920 GPM


Hydrant 07-0711 (Oak Grove Rd near Tabor Ext)

Based on the above information, the Water & Sewer department is capable of supporting the additional connections and recommends approval of the project contingent upon approval of the final plans and specifications from the Water & Sewer Department.

A motion is needed to approve and accept this project. Suggest wording is as follows:

I move to accept this water line extension project and to authorize the City manager to execute the water line extension agreement on behalf of the City.

Water & Sewer Department:	Approved Disapproved Date: 9-15-06
Hendersonville City Council:	Approved Disapproved Date:
land use plan for the municipality or H	y extension line request has been evaluated in light of the adopted lenderson County. In the absence of such a plan for the general been evaluated in terms of its future impact on existing land uses.
Approved Disapproved	
Narrative Comments Provided:	☐ Yes ☐ No



## HENDERSON COUNTY REVIEW OF CITY WATER LINE EXTENSIONS

Project Name:	Summit Springs – Off Site				
Size of Water Line	(Main & Distribution Pipe Size): 8" DIP – 1,400'.				
County Staff Review	wing Extension: Rocky Hyder, Fire Marshal; Matt Card, Subdivision Admin.; Rodney To	ucker, Proje	ct Manager		
Has the project bee	en reviewed under the County Subdivision Ordinance?	⊠ Yes	□ No	□ N/A	
Date reviewed:	May 16, 2006				
Action:	Approved with conditions.				
Conditions:	Approval of water system, final plat requirements and revisions to the development p	lan.			
Comments:					
Has the project been reviewed under the County Manufactured Park Ordinance?			□ No	⊠ N/A	
Date reviewed:					
Action:					
Conditions:					
Comments:					
Has the project been reviewed under the County Zoning Ordinance (i.e. Special-Use or Conditional-Use Permit)?			□ No	⊠ N/A	
Date reviewed:					
Action:					
Conditions:					
Comments:					
Is the project subject to any other County Land Use Ordinance?		☐ Yes	⊠ No	□ N/A	
Does the project conform with the <b>2020 Henderson County Comprehensive Plan (CCP)</b> ? The proposed water line extension project does and does not comply with the CCP. Summit Springs is located in the proposed Urban Area which encourages water and sewer services. However, the proposed site has been identified by the County's Industrial Study for a future industrial site. In this regard, the project does not comply with the recommendations of the CCP.		⊠ Yes	□ No	□ N/A	
Does the project have adequate hydrant location and spacing?		⊠ Yes	□ No	□ N/A	
Description of <b>hydr</b>	ant type and thread: Mueller Centurion – national standard thread				
Does the estimated flow rate (gpm) meet fire protection standards? Meets standard for structure spacing of 30 ft or more.		⊠ Yes	□ No	N/A	
BOARD OF COMMISSIONERS APPROVAL					
	Approved Date of Board Review:				
	Not Approved Comments:				
	Conditional Approval (See Comments)				