# **REQUEST FOR BOARD ACTION**

# Henderson County Board of Commissioners

Meeting Date:	April 16, 2008	
Subject:	Water Line Extension –Edneyville Post Office	
Attachments:	Vicinity Map Engineer's Report Project Summary Project Map County Review Sheet	

#### **Summary of Request:**


The City of Hendersonville has requested that the County comment on the proposed water line extension for the Edneyville Post Office. The proposed water line is 480 linear feet with one (1) fire hydrant. The project's location in the commercial service center within the urban/rural transition area is consistent with the Henderson County 2020 Comprehensive Plan. A City of Hendersonville Project Summary Sheet, with backup documents and County Review Sheet with Staff comments, are attached for Board review and action.

#### **Board Action Request:**

Action by the Board of Commissioners is needed to either grant or deny this request. If the Board decides to approve the requested extension the following motion has been provided.

#### **Suggested Motion:**

I move that the Board approve the Edneyville Post Office water line extension and direct Staff to convey the County's comments to the City of Hendersonville.



# **Edneyville Post Office**

OWNER/DEVELOPER: Edneyville Post Office ZONING: R-1 SEWER SYSTEM: Private Sewer

# Legend

Subject Area

Proposed Water Line Extension

- Existing Hendersonville Water Line
- Streets

Community Service Centers

Rural/Urban Transition Area

Laughter, Austin and Associates, P.A. Engineering • Planning • Land Surveying 131 FOURTH AVENUE EAST HENDERSONVILLE, NORTH CAROLINA 28792

Jon H. Laughter, PLS, PE Thomas P. Welbourn, PLS, EIT Fred S. Price, PLS

Donald J. Austin, PLS James D. Chambless, Sr., EIT

# LETTER OF TRANSMITTAL

March 3, 2008

James L. Patrick, P.E., Director City of Hendersonville Engineering Department **City of Hendersonville** P.O. Box 1670 Hendersonville, NC 28793

> Project: Edneyville Post Office Water Main Extension City of Hendersonville Water & Sewer Dept. LAA Job No. 08-049

[ ]	Application For Plan Review Final Submittal For Approval Request To Start Construction	[ ] [ ]	Preliminary Information You Requested As-Built Submittal For Your Files		<ul> <li>New Submittal [ ] Revision</li> <li>Additional Info. Requested</li> <li>Completion Certification</li> <li>Other</li> </ul>
-----	---	------------	--	--	---

Dear Mr. Patrick,

Please find the following items attached for purposes of preliminary plan review, on the aforementioned project:

- 1.) Four (4) copies of plan sheets.
- 2.) Four (4) copies of Project Narrative.
- 3.) Four (4) copies of Technical Specifications.
- 4.) Four (4) copies of Engineer's Report

Phone: 828-692-9089 • Fax: 828-693-8822 • Watts: 800-858-LAND e-mail: laapa@bellsouth.net

Laughter, Austin and Associates, P.A. Engineering • Planning • Land Surveying **131 FOURTH AVENUE EAST** HENDERSONVILLE, NORTH CAROLINA 28792

Jon H. Laughter Donald J. Austin Thomas P. Welbourn James D. Chambless, Sr.

(828) 692-9089 Fax (828) 693-8822 WATS 1-800-858-LAND

# **PROJECT NARRATIVE**

Project :	City of Hendersonville WATER LINE EXTENSION to serve Edneyville Post Office located on the north side of US 64 East and approximately 90 Feet east of SR 1722.
Project Number:	LAA08-049
Owner/Developer:	City of Hendersonville
Address:	P.O. Box 1760 Hendersonville, North Carolina 28793
Telephone:	(828) 697-3063 5.20.03

Description:

This proposed Water Main Extension is being planned to serve an existing Post Office facility in Henderson County located on the north side of US 64 East approximately 90 feet east of SR 1722. This water main extension is being done by private contractors for the City of Hendersonville's Water and Sewer Department.

This proposed water extension will require tapping into the existing 12" water main on the north side of US 64 East and running east along the north side of US 64 East for approximately 450 feet.

This extension shall be installed according to the proposed plans.

existing septic Vance Hoots, owner.

#### **PROJECT NARRATIVE**, continued

City of Hendersonville Water and Sewer Department Edneyville Post Office Water Main Extension Page-2-March 3, 2008 LAA Job No. 08-049

#### In General;

The installation of this Water Main Extension is expected to begin shortly after all approvals and permits have been issued and "authorization to start" has been given by the City's Water and Sewer Department. The utility contractor for this project will be determined at a later date and the Town Water and Sewer Department will be notified.

This is a water main extension for the City of Hendersonville Water and Sewer Department. This water main extension shall be installed in accordance with all local and state regulations by a N.C. licensed utility contractor to be selected by the Owner/Developer and approved by the Water and Sewer Department.

Laughter, Austin and Associates, P.A. (Consulting Engineers) shall provide installation monitoring services during the construction and installation process and provide completion certification when the job is completed as required by the City of Hendersonville Water and Sewer Department.

#### **ENGINEER'S REPORT**

#### FOR

#### WATER SYSTEM IMPROVEMENTS

To Serve

#### **EDNEYVILLE POST OFFICE**

#### HENDERSON COUNTY

# NORTH CAROLINA

Project Number 08-049

Prepared By:

LAUGHTER, AUSTIN & ASSOCIATES, P.A. 131 Fourth Avenue East Hendersonville, North Carolina 28792

March 3, 2008

#### ENGINEER'S REPORT EDNEYVILLE POST OFFICE WATER MAIN EXTENSION

#### NAME AND ADDRESS OF APPLICANT City of Hendersonville P.O. Box 1760 Hendersonville, NC 28793

#### 2. PROJECT DESCRIPTION & INTRODUCTION

This project is located on the north side of US 64 East and approximately 90 feet east of SR 1722 in Henderson County. This water main extension is being done by contractors for the City of Hendersonville's Water and Sewer Department.

This proposed water extension will require tapping into the existing 12" water main on the north side of US 64 East and running east along the north side of US 64 East for approximately 4500 feet. This proposed line will have installed one fire hydrant with appropriate tee's, valves and fittings.

#### 3. DESCRIPTION OF FUTURE SERVICE AREAS

This extension will serves the existing Edneyville Post Office with 3 employees. Existing lines are adequate for serving surrounding areas.

# 4. PRESENT AND ANTICIPATED WATER DEMANDS

Present water demands are to serve the 3 employees in the existing Post Office. Thus the design demand is approximately 3 employees @ 20 GPD/connection. Total demand is approximately 60 GPD.

## 5. CHARACTER OF THE SOURCE SUPPLY

The water supply for this project is from the City of Hendersonville Water Treatment Plant.

# 6. AGGREEMENTS TO PURCHASE WATER

Not applicable

## 7. USEFUL LIFE OF FACILITIES

The useful life of the water lines for this project is expected to be 50 years minimum.

# 8. MAXIMUM DAILY TREATED WATER SUPPLY AND MAXIMUM DAILY DEMAND

The maximum daily treated water supply for the City of Hendersonville water plant is 12MGD. The average demand is 7.2 MGD, with a daily peak (for the year) of 9.5 MGD

#### 9. IDENTIFICATION & DESCRIPTION OF THE SERVICE AREA

The initial service area for this project is approximately 1 Post Office with 3 employees.

# 10. CONSIDERATION OF ALTERNATIVES TO CONSTRUCTIING A NEW WATER SYSTEM.

Not applicable

#### 11. **POPULATION RECORDS AND TRENDS** Unknown

## 12. PRESENT AND FUTURE YIELD FROM THE SOURCES OF SUPPLY

The City of Hendersonville Water Plant currently draws water from the Mills River. The present and future yield of the source of supply is expected to be adequate for the City of Hendersonville's present and future needs.

# 13. PROPOSED WATER TREATMENT PROCESSES

Not Applicable

#### 14. **DESIGN BASIS**

The design basis for this project is to provide adequate flow @ 30 psi minimum at the street.

# 15. PRIORITIZED LIST OF INFRASTRUCTURE IMPROVEMENTS

Not Applicable

#### PROJECT SUMMARY WATER UTILITY EXTENSION Edneyville Post Office

#### March 24, 2008

To: Honorable Mayor and Members of City of Council

From: Water & Sewer Department Staff

RE: STAFF RECOMMENDATION FOR ACCEPTANCE OF WATER UTILITY EXTENSION AGREEMENT (WUEA)

This is a project to extend lines to provide water service to **an existing Post Office facility.** This project is located **on the north side of US 64 East approximately 90 feet east of SR 1722.** This project is under the reviewing jurisdiction of **Henderson County** and is located within the **USA – Urban Services Area** planning area. This project **will not** involve an IBT (Interbasin Transfer) from the French Broad River Basin. The entire cost of the proposed water line extension is to be paid for by **Edneyville Post Office**.

This project requires approximately 480 linear feet of water line sized as following:

Approximate Length:Description:480 If12" DIP CL 350

Fire Protection will be provided by the installation of 1-fire hydrants.


The Reviewing Jurisdiction, listed below, has completed their review of this utility extension request in regard to their adopted land use plan or in terms of its future impact on existing land uses for that local government.					
Reviewing Jurisdiction: Henderson County (sent 3-24-08)					
Signing of Official: Printed Name:	Date:				


Based on the above information, the Water & Sewer Department has the capacity to support this additional infrastructure and associated connections and hereby recommends approval of said project contingent upon final approval of construction plans and specifications by the Water & Sewer Department.

A motion is needed to approve and accept this project. Suggested wording for motion is as follows:

# *"I move to accept this Water Utility Extension Project and to authorize the City Manager to execute the associated Water Utility Extension Agreement on behalf of the City."*

Water and Sewer Department:	Approved	Disapproved	Date: 3-12-08
Henderson Co. Commissioners:	Approved	Disapproved	Date:
Hendersonville City Council:	Approved	Disapproved	Date:





12 2 2 12 Ð

LONGITUDINAL CUTS

- FINISHED GRADE

-24" X 24" X 6" CONCRETE PAD

WATER MAIN

18" MIN 24" MAX 4' MINIMUM TO BOTTOM OF DITCH

	WATERLINE DETAILS				
	EDNEYMLLE T			SON COUN	TY, N.C.
ARED	LAUGHTER, AUSTIN AND ASSOCIATES, P.A. 131 FOURTH AVENUE EAST HENDERSONVILLE, NORTH CAROLINA 28792 (228) 692–9089				
CRIPTION	CREV CHEEF D.U	CHECKED BY		DATE	SHEET NO.
	DRAVN BY FSP	SCALE 1"	20 FT.	3/03/08	2 OF 2
~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	COURD. FILE 06275	MAVING FILE 08049angr			
0. 08–049	FLOOD NAP PANEL MUNDER	TAX PARCEL HUNGER 0601-45-6401			

## HENDERSON COUNTY REVIEW OF CITY WATER LINE EXTENSIONS

Project Name: Edneyville Post Office Water Line Extension					
Size of Water Line (Main & Distribution Pipe Size):       480 If 12" DIP CL 350, 1 fire hydrant         County Staff Reviewing Extension:       Rocky Hyder, Fire Marshal; Alexis Baker, Planner; Autumn Radcliff, Senior Planner					
Has the project been reviewed under the County Subdivision Regulations of the Land Development Code?	□ Yes	□ No	⊠ N/A		
Date reviewed:					
Action:					
Conditions:					
Comments:					
Has the project been reviewed under the County Manufactured Park Regulations of the Land Development Code?	□ Yes	⊠ No	□ N/A		
Date reviewed:					
Action:					
Conditions:					
Comments:					
Has the project been reviewed under the County Zoning Regulations (i.e. Special-Use or Conditional-Use Permit)		$\boxtimes$			
of the Land Development Code?	Yes	No	N/A		
Date reviewed:					
Conditions:					
Comments:					
Is the project subject to any other County Land Use Regulations?		$\boxtimes$			
	Yes	No	N/A		
If yes, explain:					
Deep the project conform with the 2020 Handerson County Commoderative Dist (CCD)?	$\bowtie$				
Does the project conform with the 2020 Henderson County Comprehensive Plan (CCP)?	Yes	No	N/A		
Project lies in the Community Service Center within the Rural/Urban Transition Area					
Does the project have adequate hydrant location and spacing?					
Description of hydrapt type and thread, Mueller Conturion, National Standard Thread	Yes	No	N/A		
Description of hydrant type and thread: <u>Mueller Centurion – National Standard Thread</u> Does the estimated flow rate (gpm) meet fire protection standards? Meets standard for structure spacing of 31 feet or	$\boxtimes$				
more.	Yes	No	N/A		

BOARD OF COMMISSIONERS APPROVAL				
	Approved	Date of Board Review:		
	Not Approved	Comments:		
	Conditional Approval (See Comments)			