REQUEST FOR BOARD ACTION

Henderson County Board of Commissioners

Meeting Date: February 1, 2010

Subject: Water Line Extension– Mona Lisa Foods

Attachments:

1. Vicinity Map

2. Engineer's Report

3. Project Summary

4. County Review Sheet

Summary of Request:


The City of Hendersonville has requested that the County comment on the proposed water line extension for Mona Lisa Foods project. The proposed water line is 450 linear feet. The project's location, within the Rural Transition Area, is consistent with the Henderson County 2020 Comprehensive Plan. A vicinity map, engineers report, project summary, and county review sheet are attached for Board review and action.

Board Action Request:

Planning Staff requests action by the Board of Commissioners to grant or deny this request. If the Board decides to approve the requested extension, the following motion has been provided.

Suggested Motion:


I move that the Board approve the Mona Lisa Foods water line extension and direct staff to convey the County's comments to the City of Hendersonville.



Mona Lisa Foods

OWNER/DEVELOPER: Peter Thom, and Wife

ZONING: Local Commercial



Laughter, Austin and Associates, P.A.

Engineering • Planning • Land Surveying
131 FOURTH AVENUE EAST
HENDERSONVILLE, NORTH CAROLINA 28792

Jon H. Laughter, PLS, PE Thomas P. Welbourn, PLS, EIT Fred S. Price, PLS Donald J. Austin, PLS James D. Chambless, Sr., EIT

December 8, 2009

PROJECT NARRATIVE

Mr. Lee Smith, Utilities Director City of Hendersonville Water and Sewer Department

RE:

Mona Lisa Foods **0601-35-4794**

WATER UTILITY EXTENSION

An extension of the existing water main(s) located in South roadway shoulder U.S 64 East is required to provide water service to the above referenced project. This project is proposed to be an Expansion of Industrial Building. The water extension will serve a total of one building. The proposed site is currently owned and being developed by:

Peter A. Thom, Owner, Mona Lisa Foods 224 Thompson Street, Hendersonville, N.C. 28792 Physical Address: Intersection U.S. 64 and St. Paul Road, Edneyville, N.C. Contact's Telephone Number: Tom at Mona Lisa 778-9642

The sewer service for this project will be provided by Individual Septic.

At the present time, Peter Thom will be responsible for signing the Water Utility Extension Agreement (WUEA) with the City of Hendersonville.

The project will consist of 8-inch diameter ductile iron pipe, Length = 400 feet, one hydrant assembly, **estimated flow rate 1,000 gpm.** For more information regarding this proposed project see the accompanying preliminary plans.

This project is estimated to be completed *thirty* days after final grading has been completed, assuming favorable weather conditions. I, or an authorized representative of my company, will be observing and monitoring the progress of construction for this project. Should you have any questions, concerns or comments regarding this project please feel free to contact me.

Laughter, Austin and Associates, PA


Jon H. Laughter

Phone: 828-692-9089 • Fax: 828-693-8822 • Watts: 800-858-LAND

E-mail: laapa@bellsouth.net

PROJECT SUMMARY WATER UTILITY EXTENSION Mona Lisa Foods

lanua	ry 4, 2010							
To:		and Members of C	tity of Council					
	Honorable Mayor and Members of City of Council							
rioiii.	n: Water & Sewer Department Staff							
RE:	STAFF RECOMMENDATION FOR ACCEPTANCE OF WATER UTILITY EXTENSION AGREEMENT (WUEA)							
This p and is Transf	roject is located on : located within the U	St Paul Road. Tl SA – Urban Ser v Broad River Basi	his project is u vices Area. The n. The entire o	inder the revie his project will	on of an existing industrial building. wing jurisdiction of Henderson County not involve an IBT (Interbasin posed water line extension is to be paid			
This p	roject requires appro	oximately 450 line	ear feet of wat	er line sized as	s following:			
Appro: 450 '	ximate Length:	Description: 8" DIP CL 35	0					
Fire P	rotection will be prov	ided by the instal	llation of 1 -fire	hydrant.				
to thei		olan or in terms of	f its future imp		this utility extension request in regard along land uses for that local government.			
□App		ed (See attached	I form provided	d to the City by	the Reviewing Jurisdiction)			
	g of Official: d Name:			Date				
infrast		ted connections a	and hereby red	commends app	e capacity to support this additional proval of said project contingent upon ewer Department.			
A moti	on is needed to app	rove and accept t	this project. S	uggested word	ling for motion is as follows:			
	ve to accept this W iated Water Utility				rize the City Manager to execute the			
Hende	and Sewer Departmerson Co. Commissions	oners: 🔲 Api	proved 🔲 Di	sapproved sapproved sapproved	Date: 12-22-09 Date: Date:			



HENDERSON COUNTY REVIEW OF CITY WATER LINE EXTENSIONS

Project Name: Mona Lisa Foods			
Size of Water Line (Main & Distribution Pipe Size): 450 LF of 8" DIP CL350			
County Staff Reviewing Extension: Rocky Hyder, Fire Marshal; Parker Sloan, Planner; Autumn Radcliff, S	enior Plann	er	
Has the project been reviewed under the County Subdivision Regulations of the Land Development Code?	☐ Yes	⊠ No	□ N/A
Date reviewed:			
Action:			
Conditions:			
Comments:			
Has the project been reviewed under the County Manufactured Park Regulations of the Land Development Code?	☐ Yes	⊠ No	□ N/A
Date reviewed:			
Action:			
Conditions:			
Comments:			
Has the project been reviewed under the County Zoning Regulations (i.e. Special-Use or Conditional-Use Permit) of the Land Development Code?	☐ Yes	⊠ No	□ N/A
Date reviewed:			
Action:			
Conditions:			
Comments:			
Is the project subject to any other County Land Use Regulations?	☐ Yes	⊠ No	□ N/A
If yes, explain:			
Does the project conform with the 2020 Henderson County Comprehensive Plan (CCP)?	⊠ Yes	□ No	□ N/A
Does the project have adequate hydrant location and spacing ? Pursuant to the NC Fire Code, a fire hydrant must be located within 400 feet of any portion of the building. Due to the topography at the rear of the building and the building will be protected by an automatic sprinkler system, the hydrant spacing is acceptable.	⊠ Yes	□ No	□ N/A
Description of hydrant type and thread: Mueller Centurion – National Standard Thread			
Does the estimated flow rate (gpm) meet fire protection standards? Est 1000 gpm	⊠ Yes	□ No	□ N/A
BOARD OF COMMISSIONERS APPROVAL			
☐ Approved Date of Board Review: Not Approved Comments:			
Conditional Approval (See Comments)			