REQUEST FOR BOARD ACTION

HENDERSON COUNTY BOARD OF COMMISSIONERS

MEETING DATE:	Monday, November 5, 2012		
SUBJECT:	Water Line Extension- Water's Edge		
PRESENTER:	Matt Champion, Planner		
ATTACHMENTS:	 Vicinity Map Project Summary 		

3. County Review Sheets

SUMMARY OF REQUEST:


The City of Hendersonville has requested that the County comment on the proposed water line extension to the Water's Edge subdivision off Eade Road. The proposed water line is 1750 linear feet. The project's location within the Rural Transition area is consistent with the Henderson County 2020 Comprehensive Plan. A City of Hendersonville Project Summary Sheet and County Review Sheet with Staff comments are attached for Board review and action.

BOARD ACTION REQUEST:

Action by the Board of Commissioners is needed to either grant or deny this request. If the Board decides to approve the requested extension the following motion has been provided.


Suggested Motion:

I move that the Board approve the Water's Edge water line extension and direct Staff to convey the County's comments to the City of Hendersonville.



Water's Edge Water Line Extension

OWNER/DEVELOPER: Eade Road Investments, LLC ZONING: R2R ROAD SYSTEM: Private



PROJECT SUMMARY WATER UTILITY EXTENSION Waters Edge

October 3, 2012

To: Honorable Mayor and Members of City of Council

From: Water & Sewer Department Staff

RE: STAFF RECOMMENDATION FOR ACCEPTANCE OF WATER UTILITY EXTENSION AGREEMENT (WUEA)

This is a project to extend lines to provide water service to a **proposed single family development**. This project is located **on the south side of Eade Road**. This project is under the reviewing jurisdiction of **Henderson County** and is located within the **USA – Urban Services Area** planning area of Henderson County. This project **will not** involve an IBT (Interbasin Transfer). The entire cost of the proposed water line extension is to be paid for by **Eade Road Investments, LLC**.

This project requires approximately 1750 linear feet of water line sized as following:

Approximate Length:	Description:
1210 If	6" DIP CL350
540 lf	2" PVC SDR 13.5

Fire Protection will be provided by the installation of 3 (three) -fire hydrants.

The Reviewing Jurisdiction, listed below, has completed their revi to their adopted land use plan or in terms of its future impact on e	
Reviewing Jurisdiction: Henderson County	
Narrative Comments Provided: 🗌 Yes 🗌 No	
Signing Official:	Date:

Based on the above information, the Water & Sewer Department has the capacity to support this additional infrastructure and associated connections and hereby recommends approval of said project contingent upon final approval of construction plans and specifications by the Water & Sewer Department.

A motion is needed to approve and accept this project. Suggested wording for motion is as follows:

"I move to accept this Water Utility Extension Project and to authorize the City Manager to execute the associated Water Utility Extension Agreement on behalf of the City."

Water and Sewer Department:	Approved Disapproved	Date: 10-1-12
Henderson Co. Commissioners:	Approved Disapproved	Date:
Hendersonville City Council:	Approved Disapproved	Date:

HENDERSON COUNTY REVIEW OF CITY WATER LINE EXTENSIONS

Project Name: Water's Edge Residents			
Size of Water Line (Main & Distribution Pipe Size): 1210 feet 6" DIP CL 350; 540 feet 2" PVC SDR 13.5			
County Staff Reviewing Extension: Rocky Hyder, Fire Marshal; Matt Champion, Planner;			
Has the project been reviewed under the County Subdivision Regulations of the Land Development Code?		⊠ No	□ N/A
Date reviewed:	Yes		
Action:			
Conditions:			
Comments:			
Has the project been reviewed under the County Manufactured Park Regulations of the Land Development Code?	□ Yes	⊠ No	□ N/A
Date reviewed:			
Action:			
Conditions:			
Comments:			
Has the project been reviewed under the County Zoning Regulations (i.e. Special-Use or Conditional-Use Permit) of the Land Development Code?		⊠ No	□ N/A
Date reviewed:			
Action:			
Conditions:			
Comments:			
Is the project subject to any other County Land Use Regulations?		⊠ No	□ N/A
If yes, explain:			
Does the project conform with the 2020 Henderson County Comprehensive Plan (CCP)?	\boxtimes		
	Yes	No	N/A
Does the project have adequate hydrant location and spacing?	\boxtimes		
	Yes	No	N/A
Description of hydrant type and thread: Mueller Centurion – National Standard Thread	-		
Does the estimated flow rate (gpm) meet fire protection standards?			□ N/A
	Yes	No	N/A
BOARD OF COMMISSIONERS APPROVAL			
Approved Date of Board Review:			_
Not Approved Comments:			

Approved Not Approved Conditional Approval (See Comments)