


THE TAMARA PEACOCK COMPANY

Architects



The Tamara Peacock Company
104 E 1st Ave, Suite A
Hendersonville, NC 28806

July 18, 2017

Henderson County
Public Library Renovation

RE: Fire Marshal Permit Set comments

ADDENDUM 8

This addendum hereby becomes a part of the Bid Set and is to be attached to the Project Manual. The Bidder is to see that all subcontractors receive the information contained within this Addendum.

1. Response to Fire Marshal comment, adding exit signs and alarms to plans:
These drawings show existing, and (3) new exit sign locations.

Additional Specs

- N/A

Updated Forms

- N/A

RFIs (101)

- N/A

Reissued Sheets

- A002
- A102.1
- A104

4 E 1st Ave. Suite A, Hendersonville, NC

phone: 828.696.4000 Fax 828.696.4952 architects@tamarapeacock.com