


THE TAMARA PEACOCK COMPANY
Architects



The Tamara Peacock Company
104 E 1st Ave, Suite A
Hendersonville, NC 28792

August 6, 2017

Henderson County
Public Library Renovation

RE: Mandatory Pre-Bid Meeting Minutes, collected questions, Submittals, revised schedule.

ADDENDUM 2

This addendum hereby becomes a part of the Bid Set and is to be attached to the Project Manual. The Bidder is to see that all subcontractors receive the information contained within this Addendum.

Additional Specs

- See Spec div 01320 Submittals
Updated Forms
- See schedule documents,

RFIs (101)

- What thickness is the glass for Interior, and Exterior?
 1. Interior Hollow Metal Window: 1/4" Tempered Glazing
 2. Exterior Alum. Storefront Windows: Insulated Glass (2) 1/4" with .5" airspace.
- Will builders be able to access the project before or after hours?
 1. Yes, please coordinate per need. See notes in Meeting minutes.
- Are there Noise concerns?
 1. Yes, only with tenants during operating hours.
- Are the carpets removable?
 1. Yes, they are squares, remove per need.

Reissued Sheets

- A002
- A102.1
- A104
- Schedule

4 E 1st Ave. Suite A, Hendersonville, NC

PHONE: 828.696.4000 Fax 828.696.4952 architects@tamarapeacock.com